



ALEXANDRIA HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
 4480 KING STREET, ALEXANDRIA, VA 22302
 TELEPHONE: (703) 746-4910, FAX: (703) 746-4919
 WEBSITE: <http://alexandriava.gov/AquaticHealth>

Electrical Inspection for Aquatic Facility

POOL NAME:		POOL MANAGEMENT COMPANY:	
POOL ADDRESS:			
MASTER ELECTRICIAN:		REGISTRATION #:	EXPIRES:
Yes	No	Inspection Item	
<input type="checkbox"/>	<input type="checkbox"/>	Pool was filled the time of inspection.	
<input type="checkbox"/>	<input type="checkbox"/>	Checked and tightened all loose wires found in panels and/or disconnects.	
<input type="checkbox"/>	<input type="checkbox"/>	Checked breakers and fuses for looseness; working condition.	
<input type="checkbox"/>	<input type="checkbox"/>	Checked ground fault circuit interrupter (GFCI) for proper working condition.	
<input type="checkbox"/>	<input type="checkbox"/>	Checked underwater fixtures and deck boxes for leakage from worn or broken gaskets and for worn or deteriorated cords to fixtures. Also checked clamps that hold fixtures in their cases.	
<input type="checkbox"/>	<input type="checkbox"/>	Checked all pole lights and receptacles around pool for proper grounding, loose conduit connections, breakage and damaged or missing plates or covers.	
<input type="checkbox"/>	<input type="checkbox"/>	Checked all bond wires on all electrical equipment to pool.	
<input type="checkbox"/>	<input type="checkbox"/>	Checked all conduits and connectors for tight connections.	
<input type="checkbox"/>	<input type="checkbox"/>	Replaced all defective conduits, panels, disconnects, switches, troughs, pull boxes, and junction boxes, if needed.	
<p>I certify that the above listed inspections and, if needed, corrections have been performed, and this facility is in a safe condition and is in full compliance with the current National Electric Code and all other applicable codes and standards.</p>			
Date Inspected: _____		Electrician's Signature: _____	