

3001 Park Center Pool

ADDRESS: 3001 Park Center Dr
PHONE: 703 578-3001
TYPE: Local Pool - Seasonal

MANAGED BY: Sunset Pool Management

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.6	1.5			
	Wading Pool					

VIOLATION 11-11-039 flow rate observed at 130 GPM.
 OBSERVED *Correct flow rate so that it can achieve the recommended flow of 138 GPM.*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/15/2010	Main Pool	7.8	2	140		
	Wading Pool					

VIOLATION 11-11-058 (a) No record of testing for T.A. & C.H.
 OBSERVED *Test weekly and record in log book kept onsite.*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

4600 Duke Street

ADDRESS: 4600 Duke St

MANAGED BY: AquaSafe Pool Management,

PHONE: 703 376-4295

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/16/2010	Main Pool	7.6	2	300		
	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/14/2010	Main Pool	7.6	5			
	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Alexan Carlyle

ADDRESS: 800 John Carlyle St

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 736-8095

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/7/2010	Main Pool	7.8	3			
	Wading Pool					

VIOLATION
OBSERVED

11-11-046

Does not have 5ft clearance around the pool.

Clear the chairs at tha corner by the emergency gate.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Alexandria Days Inn (Pool)

ADDRESS: 110 S. Bragg St

MANAGED BY: Sunset Pool Management

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	3	80		
7/9/2010	Wading Pool					

VIOLATION OBSERVED 11-11-017 Ceiling in ladies bathhouse by water heater has a hole in it
Repair ceiling

VIOLATION OBSERVED 11-11-017 Paint stored in ladies bathhouse
Remove paint

VIOLATION OBSERVED 11-11-045 2 of 4 weirs missing
Install weirs

VIOLATION OBSERVED 11-11-059 Water quality placard last updated 7/7/2010
Update with latest water quality test results

Total # of Non-Critical Violations: 4	Inspection
Total # of Critical Violations: 0	Comments:

Alexandria Hawthorn Suites (Pool)

ADDRESS: 420 N. Van Dorn St

MANAGED BY: Sunset Pool Management

PHONE: 703 370-1000

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2	100		
7/6/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-010 (a)

CRITICAL VIOLATION. No CPO

Must have CPO at pool during pool hours

Total # of Non-Critical Violations: 0	Inspection	Issued \$100 civil fine 11-03467 for no CPO
Total # of Critical Violations: 1	Comments:	

Alexandria House

ADDRESS: 400 Madison St

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 548-5002

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.4	3			
	Wading Pool					

VIOLATION
OBSERVED

11-11-037

This is a Repeat Violation. Flow rate observed at 70 GPM.
Raise flow rate to 75 GPM.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Alexandria Knolls West

ADDRESS: 6101 Edsall Rd

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 751-7541

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/13/2010	Main Pool	7.5	1	140		
	Wading Pool	7.6	3	45		

VIOLATION OBSERVED 11-11-046 This is a Repeat Violation. Planters are too close to pool
Move planters at least five feet away from pool edge

VIOLATION OBSERVED 11-11-081 This is a Repeat Violation. Spa lacks vertical depth markings
Provide a minimum of 2 depth markings on ther vertical surface of the tiles

VIOLATION OBSERVED 11-11-103 T.A. for spa is 40 ppm
Raise to 60-180 ppm

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 0	

Archstone Newport Village

ADDRESS: 4757 W. Braddock Rd **MANAGED BY:** Premier Aquatics
PHONE: 703 578-3300
TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/17/2010	Main Pool	7.4	3			
	Wading Pool					

VIOLATION OBSERVED 11-11-069 (c) **CRITICAL VIOLATION.** This is a Repeat Violation.
 Chlorine level for wading pool is observed at +5.0 ppm.
Lower Cl level to 1 - 5 ppm

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

Aspen House

ADDRESS: 3201 Landover St

MANAGED BY: Premier Aquatics

PHONE: 703 683-1215

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/14/2010	Main Pool	7.6	2			
	Wading Pool					

VIOLATION
OBSERVED

11-11-039

Flow rate is observed at 245 GPM after a back washed.
*The minimum required flow for the system is 260 GPM.
Correct the flow so that it can achieve the system's
commendation.*

VIOLATION
OBSERVED

11-11-058 (a)

Water quality placard is very messy.
Provide a better way of posting water data.

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Avalon At Cameron Court

ADDRESS: 2700 Williamsburg St **MANAGED BY:** Continental Pools, Inc.
PHONE: 703 567-5399
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/7/2010	Main Pool	7	3			
	Wading Pool					

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Combined chlorine (C.C.) for main pool is 0.4ppm.
C.C. must be at 0 - 0.2ppm.

VIOLATION OBSERVED 11-11-069 (c)' Main pool's pH = 2.0
pH must be 7.2 - 7.8. Pool must be closed.

VIOLATION OBSERVED 11-11-069 (d) CRITICAL VIOLATION. CYA for pool is 65.
CYA must be 0 - 50ppm.

Total # of Non-Critical Violations: 1	Inspection	According to the chemical log book, pH is at 7.0 since
Total # of Critical Violations: 2	Comments:	3:00pm 07/07/2010.

Aventine of Alexandria, The

ADDRESS: 2801 Park Center Dr **MANAGED BY:** U.S. Aquatics
PHONE: 240 235-1234
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.6	2			
	Wading Pool					

VIOLATION 11-11-017 Debris at the bottom of the pool.
OBSERVED *Vacuum the pool.*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Barton's Crossing

ADDRESS: 205 Century Pl

MANAGED BY: High Sierra Pools, Inc

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION: Routine DATE: 7/6/2010		PH	Chlorine	Flow	Temp	Pressure
	Main Pool	7.6	2	140		
	Wading Pool					

VIOLATION
OBSERVED

11-11-046

This is a Repeat Violation. Perimeter of deck around pool not clear to five feet from pool edge

Move chairs at 3 ft depth side of pool to clear deck five feet from pool edge

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Bennington Crossing

ADDRESS: 441 N. Armistead St

MANAGED BY: Continental Pools, Inc.

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.4	5	250		
DATE: 7/9/2010	Wading Pool	7.2	5	60		

VIOLATION OBSERVED 11-11-045 This is a Repeat Violation. Missing 1 weir at 5 ft depth by guard chair
Install weir

VIOLATION OBSERVED 11-11-069 (c)' T.A. for wading pool is 40 ppm.
Raise to 60 - 180 ppm.

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Bolling Brook Condominium

ADDRESS: 3240 S. 28Th St

MANAGED BY: Community Pool Service

PHONE: 703 931-3660

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.7	2.5			
7/17/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-064 (b)

CRITICAL VIOLATION. Vacuum adapter is still attached to vacuum port on pool wall.

Remove adapter and cap vacuum port.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

Braddock Place Condo Pool

ADDRESS: 1200 Braddock Pl

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 548-5184

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	3			
7/13/2010	Wading Pool					

VIOLATION 11-11-069 (c)' T.A. for spar is 40.
OBSERVED *Raise T.A. to 60 - 180.*

VIOLATION 11-11-069 (c)' Total Dissolved Solid for spa is 2220ppm.
OBSERVED *Lower it to 0 - 1600ppm.*

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Brent Place

ADDRESS: 375 S. Reynolds St

MANAGED BY: Community Pool Service

PHONE: 703 370-6080

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.6	3	181		
DATE: 7/13/2010	Wading Pool					

VIOLATION 11-11-041 Fill spout is broken
OBSERVED *Repair fill spout*

VIOLATION 11-11-052 Drinking fountain is leaking
OBSERVED *Repair fountain*

Total # of Non-Critical Violations: 2	Inspection	Wading pool was closed by pool operator prior to
Total # of Critical Violations: 0	Comments:	inspection due to pipe leaking

Calvert, The

ADDRESS: 3110 Mt. Vernon Ave
PHONE: 703 548-1446
TYPE: Local Pool - Seasonal

MANAGED BY: High Sierra Pools, Inc

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/17/2010	Main Pool	7.6	3.6	110		
	Wading Pool					

VIOLATION OBSERVED 11-11-064 (b) CRITICAL VIOLATION. Missing 2 of 2 emergency blankets
Provide blankets prior to opening tomorrow

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/10/2010	Main Pool	7.6	3			
	Wading Pool					

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Cameron Run Regional Park/Slide

ADDRESS: 4001 Eisenhower Ave

MANAGED BY: Self-Managed

PHONE: 703 960-0767 x101

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	2.5			
7/15/2010	Wading Pool					

VIOLATION OBSERVED 11-11-046 White caulking at the bottom of the slide is cracked (plastic).
Repair caulking.

VIOLATION OBSERVED 11-11-069 (c)' Calcium hardness is observed at 120.
Raise it to 150 - 1000.

VIOLATION OBSERVED 11-11-069 (c)' Total Alkalinity is observed at 50.
Raise it to 60 - 180.

Total # of Non-Critical Violations: 3	Inspection
Total # of Critical Violations: 0	Comments:

Cameron Run Regional Park/Wave Pool

ADDRESS: 4001 Eisenhower Ave

MANAGED BY: Self-Managed

PHONE: 703 960-0767 x101

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	4			
7/15/2010	Wading Pool					

VIOLATION 11-11-069 (c)' Calcium hardness is observed at 140.
 OBSERVED *Increase C.H. to 150 - 1000.*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Cameron Run Regional Pk. Tot & Wading Pool

ADDRESS: 4001 Eisenhower Ave

MANAGED BY: Self-Managed

PHONE: 703 960-0767 x101

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.6	3			
DATE: 7/15/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-058 (a)

T.A., C.H., and CYA are not recored weekly in the chemical log book.

Those 3 tests must be tested and recorded once a week.

VIOLATION
OBSERVED

11-11-069 (c)'

C.H. for tot pool is observed at 130.

Increase it to 150 - 1000.

VIOLATION
OBSERVED

11-11-069 (c)'

Calcium hardness for wading pool is observed at 120.

Increase C.H. to 150 - 1000.

Total # of Non-Critical Violations: 3

Total # of Critical Violations: 0

Inspection
Comments:

Cameron Station Community Assoc. Pool

ADDRESS: 200 Cameron Station Blvd **MANAGED BY:** Community Pool Service

PHONE: 703 567-4881

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2	325		
7/13/2010	Wading Pool	7.8	1.5	30		

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Canal Place Condominium

ADDRESS: 1117 N. Pitt St

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 683-1043

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.6	5	85		
	Wading Pool					

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.6	2			
	Wading Pool					

VIOLATION OBSERVED 11-11-064 (a) CRITICAL VIOLATION. Body hook is not bolted to long pole.
Attach body hook to pole.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

Canterbury Square

ADDRESS: 5201 Duke St

MANAGED BY: Atlantic Pool Service

PHONE: 703 751-2300

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	3	250		
7/14/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Carlyle Place Condominiums

ADDRESS: 2251 Eisenhower Ave **MANAGED BY:** U.S. Aquatics
PHONE: 703
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	2.5			
7/7/2010	Wading Pool					

VIOLATION OBSERVED 11-11-007 CRITICAL VIOLATION. 2010 Health Permit is located inside guard room.
Post Health Permit in a conspicuous area.

Total # of Non-Critical Violations: 0	Inspection Comments:
Total # of Critical Violations: 1	

Carlyle Towers Condominium

ADDRESS: 2121 Jamieson Ave

MANAGED BY: Deep Blue Aquatics, Inc.

PHONE: 703 567-2151

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	2			
7/7/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection	Great Guard!
Total # of Critical Violations: 0	Comments:	

Carlyle Towers Condominium (Pool)

ADDRESS: 2121 Jamieson Ave

MANAGED BY: Self-Managed

PHONE: 703 567-2151

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	3			
7/7/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-039

This is a Repeat Violation. Flow meter for small spa is stuck.

Fix meter.

VIOLATION
OBSERVED

11-11-069 (c)'

Calcium hardness for large spa is 110.

Raise it to 150 - 1000.

VIOLATION
OBSERVED

11-11-069 (c)'

Combined chlorine for small spa is 0.4ppm.

Reduce combined chlorine to 0 - 0.2ppm.

VIOLATION
OBSERVED

11-11-099

This is a Repeat Violation. Temperature of large spa is 105°F.

Reduce temperature to 90 - 104°F.

Total # of Non-Critical Violations: 4

Total # of Critical Violations: 0

Inspection
Comments:

Carydale East Apartments

ADDRESS: 2727 Duke St

MANAGED BY: American Pool Company

PHONE: 703 823-5544

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2.0			
7/16/2010	Wading Pool					

VIOLATION OBSERVED 11-11-045 This is a Repeat Violation. 2 weirs are still missing from skimmers.
Replace missing weirs.

VIOLATION OBSERVED 11-11-052 Drinking fountain is not working.
Fix fountain.

VIOLATION OBSERVED 11-11-069 (e) Squirt bottle to test cyanuric acid test is not available.
Provide bottle.

Total # of Non-Critical Violations: 3	Inspection
Total # of Critical Violations: 0	Comments:

Cascade At Landmark Pool

ADDRESS: 300 Yoakum Pkwy

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 461-3636

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/9/2010	Main Pool	7.6	1	200		
	Wading Pool					

VIOLATION
OBSERVED

11-11-028

Lifeguard does not have key to emergency gate closest to the driveway

Provide key to lifeguard

Total # of Non-Critical Violations: 1	Inspection	There is another emergency gate next to the building that can be used for emergencies and is readily opened
Total # of Critical Violations: 0	Comments:	

Courtyard - Alexandria Pentagon South

ADDRESS: 4641 Kenmore Ave

MANAGED BY: Sunset Pool Management

PHONE: 703 751-4510

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.7	3	80		
7/10/2010	Wading Pool					

VIOLATION OBSERVED 11-11-037 Flow rate for pool is 80 GPM
Raise to 95 GPM prior to opening tomorrow

VIOLATION OBSERVED 11-11-059 Water quality placard not updated
Update with latest water quality test results, time, & date

VIOLATION OBSERVED 11-11-064 (a) CRITICAL VIOLATION. Body hook not attached to pole
Attach during pool hours

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 1	Comments:

Eaton Square at Arlington Ridge

ADDRESS: 801 Four Mile Rd

MANAGED BY: High Sierra Pools, Inc

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	3			
7/13/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-064 (a)

CRITICAL VIOLATION. Body hook is not attached to long pole.

Attach hook to pole.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

Edsall Bluff Condo

ADDRESS: 6151 Edsall Rd

MANAGED BY: Premier Aquatics

PHONE: 703 532-5005

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/9/2010	Main Pool	7.3	3	220		
	Wading Pool	7.4	3	22		

VIOLATION 11-11-056 Algae developing at deep end
OBSERVED *Clean algae*

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Edsall Terrace

ADDRESS: 6250 Edsall Rd

MANAGED BY: Winkler Pool Management

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/15/2010	Main Pool	7.6	3	150		
	Wading Pool					

VIOLATION OBSERVED 11-11-041 This is a Repeat Violation. Repaired sections of influent and backwash piping not color coded
Color influent sections now white to yellow and backwash sections now white to black. Add directional arrows

VIOLATION OBSERVED 11-11-064 (a) CRITICAL VIOLATION. Missing pocket mask.
Provide pocket mask prior to opening tomorrow.

VIOLATION OBSERVED 11-11-064 (b) CRITICAL VIOLATION. Missing 1 of 2 emergency blankets.
Provide a second emergency blanket prior to opening tomorrow.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 2	

Embassy Suites Hotel Pool

ADDRESS: 1900 Diagonal Rd

MANAGED BY: High Sierra Pools, Inc

PHONE: 703

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	3			
7/9/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-039

Flow rate for pool is 38 GPM.

The minimum required flow for the system is 52 GPM.

VIOLATION
OBSERVED

11-11-069 (c)

CRITICAL VIOLATION. This is a Repeat Violation.

Combined chlorine for pool and spa are 1.6 ppm and 2.2 ppm respectively.

Combined chlorine must be lower to 0 - 0.2 ppm within 24 hours.

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 1	Comments:

EOS North

ADDRESS: 140 S. Van Dorn St

MANAGED BY: Community Pool Service

PHONE: 703 212-2672

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/10/2010	Main Pool	7.4	2	160		
	Wading Pool					

VIOLATION
OBSERVED

11-11-037

Flow rate is 160 GPM. Need min 180 GPM
Raise flow rate

VIOLATION
OBSERVED

11-11-058 (a)

No record of testing for total alkalinity, calcium hardness,
and CYA since 6/13/2010
Test weekly and record in log book

VIOLATION
OBSERVED

11-11-059

Water quality placard not updated
Update with latest water quality test results, time, & date

Total # of Non-Critical Violations: 3
Total # of Critical Violations: 0

Inspection
Comments:

EOS South

ADDRESS: 140 S. Van Dorn St

MANAGED BY: Community Pool Service

PHONE: 703 212-2672

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2	250		
7/10/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-058 (a)

No record of testing for T.A., C.H., or CYA

Test weekly and record in log book kept onsite

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Exchange @ Van Dorn

ADDRESS: 4840 Eisenhower Ave
PHONE: 703 751-4756
TYPE: Local Pool - Seasonal

MANAGED BY: American Pool Company

INSPECTION: Routine DATE: 7/13/2010		PH	Chlorine	Flow	Temp	Pressure
	Main Pool	7.6	3			
	Wading Pool					

VIOLATION OBSERVED 11-11-046 This is a Repeat Violation. Does not have a 5ft clearance around the pool.
Remove long chairs between the 4ft and 5ft depth markings.

VIOLATION OBSERVED 11-11-069 (e) Does nto have the squirt bottle to perform CYA test.
Provide bottle to perform cyanuric acid test.

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Fairlington Village North #6

ADDRESS: 2920 S. Dinwiddie St **MANAGED BY:** Continental Pools, Inc.

PHONE: 703 379-1440

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	3			
7/17/2010	Wading Pool					

VIOLATION 11-11-017 Pool bottom is dirty.
OBSERVED *Vacuum the pool.*

VIOLATION 11-11-056 Algae growth observed at the deep end of the pool.
OBSERVED *Clean up algae growth.*

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Fields of Alexandria, The

ADDRESS: 4309 Duke St.

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 823-0077

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/16/2010	Main Pool	7.8	1			
	Wading Pool					

VIOLATION
OBSERVED

11-11-017

This is a Repeat Violation. One of two light fixtures in the pump room is not working.
Repair light fixture.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Fields of Landmark, The

ADDRESS: 346 S. Whiting St

MANAGED BY: Winkler Pool Management

PHONE: 703 226-6044

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.4	2	290		
DATE: 7/13/2010	Wading Pool	7.4	0.5	22		

VIOLATION OBSERVED 11-11-008 CRITICAL VIOLATION. Main drain cover for wading pool is loose: missing 1 of 2 screws
Wading pool closed until cover is secure

VIOLATION OBSERVED 11-11-017 Main pool surface damaged in deep end
Repair white coat

VIOLATION OBSERVED 11-11-017 White coat of wading pool is missing approx 3" chip
Repair white coat

VIOLATION OBSERVED 11-11-056 Deck drain beneath showers is clogged
Unclog drain

VIOLATION OBSERVED 11-11-056 Deck drain clogged by fence between main pool deck and playground with an inch of standing water approx 8 ft long and 4 ft wide
Unclog deck drain

VIOLATION OBSERVED 11-11-059 Water quality placard is unused in 2010
Update with latest water quality test results, time, & date

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Cl for wading pool is 0.5 ppm
Raise to 1-5 ppm

Total # of Non-Critical Violations: 5	Inspection Comments:
Total # of Critical Violations: 2	

Fort Ellsworth Condominium Pool

ADDRESS: 136 Roberts Ln.

MANAGED BY: Premier Aquatics

PHONE: 703 532-5005

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	2.5			
7/16/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Fountains Condominium

ADDRESS: 301 N. Beauregard St **MANAGED BY:** High Sierra Pools, Inc
PHONE: 703 354-1304
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.5	3	400		
	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Foxchase Of Alexandria - Derbyshire

ADDRESS: 4520 Taney Ave

MANAGED BY: Winkler Pool Management

PHONE: 703 751-8440

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Follow-up	Main Pool	7.5	2	350		
DATE: 7/17/2010	Wading Pool					

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection Comments:	Purpose of visit was to observe the flow rate. Rate of 310 GPM is OK for 6 hour turnover
Total # of Critical Violations: 0		

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.4	0.5	250		
DATE: 7/16/2010	Wading Pool					

VIOLATION OBSERVED 11-11-037 Flow rate is 250 gpm
Raise to 310 gpm prior to opening tomorrow

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Cl is 0.5 ppm.
Raise to 1 - 5 ppm

VIOLATION OBSERVED 11-11-069 (c)' CH is 120 ppm.
Raise to 150 - 1000 pm.

Total # of Non-Critical Violations: 2	Inspection Comments:	
Total # of Critical Violations: 1		

Foxchase Of Alexandria - Huntingwood

ADDRESS: 513 N. Howard St

MANAGED BY: Winkler Pool Management

PHONE: 703 751-8440

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/16/2010	Main Pool	7.6	1.0			
	Wading Pool					

VIOLATION
OBSERVED

11-11-017

Return inlet cover in front of guard's high chair is loose.
Secure cover.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Foxchase Of Alexandria - Longpath

ADDRESS: 710 N. Imboden St

MANAGED BY: Winkler Pool Management

PHONE: 703 751-8440

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Follow-up						
DATE: 7/17/2010	Main Pool	7.8	0.5	400		
	Wading Pool					

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Chlorine is 0.5 ppm.
Raise to 1 - 5 ppm.

Total # of Non-Critical Violations: 0	Inspection Comments:	Purpose of visit was to check for presence of chemical safety goggles and pocket mask (PPE for CPR). Goggles and pocket mask are present
Total # of Critical Violations: 1		

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/16/2010	Main Pool	7.6	2	400		
	Wading Pool					

VIOLATION OBSERVED 11-11-041 Vacuum pipe valve handle is broken
Replace handle

VIOLATION OBSERVED 11-11-064 (a) CRITICAL VIOLATION. Missing pocket mask.
Provide pocket mask prior to opening tomorrow.

VIOLATION OBSERVED 11-11-064 (b) CRITICAL VIOLATION. Missing chemical safety goggles.
Provide goggles prior to opening tomorrow.

Total # of Non-Critical Violations: 1	Inspection Comments:	
Total # of Critical Violations: 2		

Foxchase Of Alexandria - Saddlebow

ADDRESS: 4424 Taney Ave

MANAGED BY: Winkler Pool Management

PHONE: 703 751-8440

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/16/2010	Main Pool	7.4	2	350		
	Wading Pool					

VIOLATION
OBSERVED

11-11-045

Missing 1 of 10 weirs

Replace weir at 3 1/2 ft depth

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Foxwood Place

ADDRESS: 250 S. Whiting St.

MANAGED BY: Premier Aquatics

PHONE: 703 370-5577

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/14/2010	Main Pool	7.5	3	275		
	Wading Pool					

VIOLATION
OBSERVED

11-11-052

Water cooler is empty

Provide drinking water at pool by 6pm tonight

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Goodwin House

ADDRESS: 4800 Fillmore Ave

MANAGED BY: Deep Blue Aquatics, Inc.

PHONE: 703 575-5219

TYPE: Local Pool - Year Round

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/10/2010	Main Pool	7.2	1	110		
	Wading Pool					

VIOLATION OBSERVED 11-11-010 (a) CRITICAL VIOLATION. No certified pool operator at beginning of inspection
[CPO must be present during pool hours]

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. C.C. for pool is 0.4 ppm
Lower to 0-0.2 ppm

VIOLATION OBSERVED 11-11-099 This is a Repeat Violation. Temperature of water in spa is 104.9 F
Lower to max 104 F

VIOLATION OBSERVED 11-11-103 pH of spa is 8
Lower to 7.2-7.8

Total # of Non-Critical Violations: 2	Inspection	Issued \$100 civil fine 11-03473 for no certified pool operator
Total # of Critical Violations: 2	Comments:	

Greenhouse, The

ADDRESS: 5300 Holmes Run Pkwy **MANAGED BY:** High Sierra Pools, Inc
PHONE: 703 370-0340
TYPE: Local Pool - Seasonal

INSPECTION: Routine DATE: 7/13/2010		PH	Chlorine	Flow	Temp	Pressure
	Main Pool	7.4	1	550		
	Wading Pool					

VIOLATION OBSERVED 11-11-017 1 tarp anchor at 8 - 8 1/2 ft depth protrudes from deck
Lower tarp anchor flush with deck

VIOLATION OBSERVED 11-11-064 (a) CRITICAL VIOLATION. Rescue tube is cracked in several places at least halfway through tube
Replace rescue tube

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 1	

Hallmark Condominium

ADDRESS: 200 N. Pickett St

MANAGED BY: Premier Aquatics

PHONE: 703 751-0777

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	3	220		
7/14/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection	Post recreational water facility permit where patrons can
Total # of Critical Violations: 0	Comments:	read it

Halstead Towers

ADDRESS: 4380 King St.

MANAGED BY: High Sierra Pools, Inc

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.4	3.0			
	Wading Pool					

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/10/2010	Main Pool	7.5	2	140		
	Wading Pool					

VIOLATION OBSERVED 11-11-099 Spa temp is 105.5 F
Lower to max 104 F

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Hampton Inn - Old Town Alexandria

ADDRESS: 1616 King St

MANAGED BY: Community Pool Service

PHONE: 703 299-9900

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.5	2			
7/6/2010	Wading Pool					

VIOLATION OBSERVED 11-11-041 No directional arrows on parts of effluent piping.
Provide arrows.

VIOLATION OBSERVED 11-11-041 Repaired section of effluent piping is color white.
Color code effluent piping yellow.

VIOLATION OBSERVED 11-11-069 (c)' C.H. = 140
Raise calcium hardness to 150 - 1000

VIOLATION OBSERVED 11-11-069 (e) Reagent R-0013 is empty.
Provide reagent R-0013.

Total # of Non-Critical Violations: 4	Inspection
Total # of Critical Violations: 0	Comments:

High Pointe Condominium

ADDRESS: 5911 Edsall Rd

MANAGED BY: American Pool Company

PHONE: 703 751-5225

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2.5	80		
7/13/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-037

This is a Repeat Violation. Flow rate for main pool is 80 gpm. Need 125 gpm
Raise flow rate

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Hillwood At Landmark

ADDRESS: 283 S. Pickett St

MANAGED BY: Continental Pools, Inc.

PHONE: 703 426-1406

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Follow-up	Main Pool	7.3	3	100		
DATE: 7/15/2010	Wading Pool					

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection Comments:	Purpose of this visit was to observe the operation of the chlorinator. The chlorinator is working properly. The problem yesterday was that a GFCI at the electrical outlet had tripped and simply needed to be reset. (An electrical storm/thunderstorm h
Total # of Critical Violations: 0		

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.6	1	95		
DATE: 7/14/2010	Wading Pool					

VIOLATION OBSERVED 11-11-049 Chlorinator is not working
Fix chlorinator prior to opening tomorrow

Total # of Non-Critical Violations: 1	Inspection Comments:	Maintain at least 2 ppm chlorine at pools using cyanuric acid
Total # of Critical Violations: 0		

Hilton Alexandria (Pool)

ADDRESS: 5000 Seminary Rd

MANAGED BY: Sunset Pool Management

PHONE: 703 845-1010

TYPE: Local Pool - Year Round

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/17/2010	Main Pool	7.4	1.4			
	Wading Pool					

VIOLATION
OBSERVED

11-11-064 (b)

CRITICAL VIOLATION. Vacuum adapter is attached on vacuum port.

Remove adapter and cap vacuum port.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/9/2010	Main Pool	7.3, 7.5	1.6, 1.2	45, 75		
	Wading Pool					

VIOLATION
OBSERVED

11-11-069 (c)

CRITICAL VIOLATION. C.C. for indoor pool is 0.6 ppm.

Lower to 0 - 0.2 ppm.

Total # of Non-Critical Violations: 0	Inspection	Note: Pool has two filter systems. Listed values are for indoor, outdoor systems, respectively.
Total # of Critical Violations: 1	Comments:	

Holiday Inn Eisenhower Metro

ADDRESS: 2460 Eisenhower Ave **MANAGED BY:** Sunset Pool Management

PHONE: 703 960-3400 x 1112

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	2			
7/13/2010	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Holiday Inn Historic District (Pool)

ADDRESS: 625 First St

MANAGED BY: Sunset Pool Management

PHONE: 703 548-6300

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4, 7.6	2.6, 2.0	< 60, 160		
7/17/2010	Wading Pool					

VIOLATION OBSERVED 11-11-039 This is a Repeat Violation. Flow meter for indoor pool is useless. Currently it is impossible to tell flow rate when it is below 60 GPM, like it is today. Required rate is 43 GPM
Replace prior to opening on Tuesday July 20

Total # of Non-Critical Violations: 1	Inspection	Readings are for indoor, and outdoor recirculation
Total # of Critical Violations: 0	Comments:	systems, respectively

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.5	2.5			
7/6/2010	Wading Pool					

VIOLATION OBSERVED 11-11-039 This is a Repeat Violation. Flow meter for indoor system is incorrectly sized.
Provide the correct flow meter.

VIOLATION OBSERVED 11-11-068 CRITICAL VIOLATION. Main drain/bottom of pool could not be seen from deck.
Clean up water.

Total # of Non-Critical Violations: 1	Inspection	
Total # of Critical Violations: 1	Comments:	

Hotel Monaco (Pool)

ADDRESS: 480 King St

MANAGED BY: Virginia Pool Services, Inc.

PHONE: 703 549-6080

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/9/2010	Main Pool	7.4	1			
	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) Do not have T.A., C.H., and CYA recorded in the chemical log book.
These 3 tests must be perform once a week.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Combined chlorine is 0.4ppm.
Lower combined chlorine to 0.2ppm or lower.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 1	

Hunting Point on the Potomac Pool

ADDRESS: 1204 S. Washington St **MANAGED BY:** Community Pool Service
PHONE: 703 567-2828
TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/9/2010	Main Pool	7.6	2			
	Wading Pool					

VIOLATION OBSERVED 11-11-017 8ft depth markings are faded.
Restencil markings.

VIOLATION OBSERVED 11-11-017 Coping stone next to the 8ft depth marking is chipping off.
Repair coping stone.

VIOLATION OBSERVED 11-11-038 There is a bee hive on top of the light fixture.
Remove bee hive and bees.

VIOLATION OBSERVED 11-11-058 (a) Water quality placard is not clear.
Provide erasable markers.

Total # of Non-Critical Violations: 4	Inspection
Total # of Critical Violations: 0	Comments:

Jefferson @ Carlyle Mill

ADDRESS: 2201 Mill Rd

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 739-0557

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/7/2010	Main Pool	7.8	5			
	Wading Pool					

VIOLATION OBSERVED 11-11-017 Handrail on small pool is loose.
Secure handrail.

VIOLATION OBSERVED 11-11-046 Doe not have 5ft clearance around the pool.
Move long chairs back.

VIOLATION OBSERVED 11-11-069 (c)' No record of CYA, T.A., and C.H. recorded in the log book.
Record these 3 tests once a week. Final warning.

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 0	

John Ewald Pool

ADDRESS: 4500 Duke St

MANAGED BY: City of Alexandria

PHONE: 703 519-2160

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.1	1.5			
7/14/2010	Wading Pool					

VIOLATION OBSERVED 11-11-010 (c) An individual with an original CPO certificate is not onsite.
A certified individual must be present during hours of operation.

VIOLATION OBSERVED 11-11-039 This is a Repeat Violation. Flow meter is stuck at 240 GPM.
Fix flow meter so that flow can be measured accurately.

VIOLATION OBSERVED 11-11-041 Hose bib outside guard room does not have a vacuum breaker.
Provide vacuum breaker.

VIOLATION OBSERVED 11-11-069 (c)' This is a Repeat Violation. pH is observed at 7.1.
Raise pH to 7.2 - 7.8.

Total # of Non-Critical Violations: 4	Inspection
Total # of Critical Violations: 0	Comments:

Key Towers

ADDRESS: 6060 Tower Crt

MANAGED BY: Winkler Pool Management

PHONE: 703 751-6600

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/9/2010	Main Pool	7.6	2	180		
	Wading Pool					

VIOLATION OBSERVED 11-11-059 Water quality placard missing, pool rules placard missing, recreational water facility permit missing
Post placards and facility permit where patrons can read them. Update water quality placard with latest test results, time, & date

VIOLATION OBSERVED 11-11-066 (a) Water contamination/health notice/showering placard missing
Post placard where patrons can read it

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Landmark Ridge Pool

ADDRESS: 6161 Edsall Rd

MANAGED BY: Self-Managed

PHONE: 301 588-8144

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/14/2010	Main Pool	7.3	2	180		
	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) No record of testing for T.A., C.H., and CYA in log book
Test weekly and record in log book kept onsite

VIOLATION OBSERVED 11-11-069 (c)' C.H. is 140 ppm
Raise to 150-1000 ppm

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Landmark Terrace

ADDRESS: 5803 Edsall Rd

MANAGED BY: Community Pool Service

PHONE: 703 751-7733

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.8	2	260		
7/13/2010	Wading Pool					

VIOLATION 11-11-010 (a) CRITICAL VIOLATION. No CPO
 OBSERVED *CPO arrived at end of inspection*

Total # of Non-Critical Violations: 0	Inspection	Issued \$100 civil fine 11-03474 for no CPO.
Total # of Critical Violations: 1	Comments:	

Linc, The

ADDRESS: 6100 Lincolnia Rd

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 464-7800

TYPE: Local Pool - Seasonal

INSPECTION: Routine DATE: 7/6/2010		PH	Chlorine	Flow	Temp	Pressure
	Main Pool	7.5	2	90		
	Wading Pool					

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

London Park Towers

ADDRESS: 5375 Duke St

MANAGED BY: Winkler Pool Management

PHONE: 703 567-2900

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	1	250		
7/7/2010	Wading Pool					

VIOLATION OBSERVED 11-11-017 Ladder at 4 ft depth by emergency gate is loose
Secure to deck

VIOLATION OBSERVED 11-11-058 (a) No record of testing for total alkalinity, calcium hardness, and cyanuric acid (if used at this pool) in log book
Test once per week and record in log book

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Marina Towers Condominium

ADDRESS: 501 Slaters Ln

MANAGED BY: Winkler Pool Management

PHONE: 703 549-0660, ext 104

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.8	2	240		
	Wading Pool					

VIOLATION 11-11-069 (c)' Total dissolved solids (TDS) is 1690 ppm.
OBSERVED *Lower to 0 - 1600 ppm.*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.6	.5			
	Wading Pool					

VIOLATION 11-11-017 Chemical miser does not have a cap.
OBSERVED *Provide a cap or a new mixing apparatus.*

VIOLATION 11-11-017 Chlorinator is not working.
OBSERVED *Fix chlorinator.*

VIOLATION 11-11-064 (b) CRITICAL VIOLATION. Vacuum port is not capped.
OBSERVED *Cap vacuum port.*

VIOLATION 11-11-069 (c) CRITICAL VIOLATION. Cl = 0.5 ppm, there were 2
OBSERVED swimmers inside the pool.
Cl level must be 1 - 5 ppm.

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 2	Comments:

Mark Center Club

ADDRESS: 5708 Merton Crt

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 578-7850

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/9/2010	Main Pool	7.6	3	475		
	Wading Pool	7.4	5	30		

VIOLATION OBSERVED 11-11-038 1 of 2 light fixtures in filter room is unshielded
Shield light

VIOLATION OBSERVED 11-11-038 This is a Repeat Violation. 1 of 2 lights in filter room is out, the other is flickering
Repair light and/or replace tubes

VIOLATION OBSERVED 11-11-069 (c)' TDS in wading pool is 1970 ppm
Lower to 0-1600 ppm

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 0	

Mayflower Square Condo

ADDRESS: 414 N. Armistead St **MANAGED BY:** Premier Aquatics
PHONE: 703 532-5005
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	5	350		
7/7/2010	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Meadow Creek

ADDRESS: 5534 Ascot Crt

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 578-9300

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.6	2	575		
DATE: 7/7/2010	Wading Pool	7.4	0	?		

VIOLATION OBSERVED 11-11-008 CRITICAL VIOLATION. Chlorine in wading pool is 0 ppm
Wading pool closed until chlorine is 1-5 ppm and flow sufficient for two hour turnover

VIOLATION OBSERVED 11-11-017 This is a Repeat Violation. Deck drain near wading pool is clogged
Unclog

VIOLATION OBSERVED 11-11-052 Fountain leaking and algae growing on deck
Repair fountain and clean deck

VIOLATION OBSERVED 11-11-056 Algae at transition line of main pool
Clean algae from pool

VIOLATION OBSERVED 11-11-069 (c)' C.H. in main pool is 110 pm
Increase to 150-1000 ppm

VIOLATION OBSERVED 11-11-069 (c)' C.H. in wading pool is 90 ppm
Increase to 150-1000 ppm

VIOLATION OBSERVED 11-11-069 (c)' Chlorine in wading pool is 0 ppm
Raise to 1-5 ppm

VIOLATION OBSERVED 11-11-135 This is a Repeat Violation. 4 of 6 liquid soap dispensers not working in ladies shower stalls, and 1 missing
Provide working soap dispensers in all shower stalls

VIOLATION OBSERVED 11-11-135 This is a Repeat Violation. Missing 1 of 2 liquid soap dispensers in men's shower stall
Install liquid soap dispenser

VIOLATION OBSERVED 11-11-136 1 toilet broken in ladies bathhouse and 1 toilet broken in mens bathhouse
Repair toilets

VIOLATION OBSERVED 11-11-137 Faucet of sink in mens bathhouse is loose
Repair faucet

Total # of Non-Critical Violations: 10	Inspection Comments:	Issued \$100 civil fines 11-03468 and 11-03469 for low calcium hardness and lack of soap dispensers in shower stalls
Total # of Critical Violations: 1		

Memorial Pool

ADDRESS: 901 Wythe St

MANAGED BY: City of Alexandria

PHONE: 703 746-5435

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	1.5			
7/16/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-063 (b)

CRITICAL VIOLATION. Guard +3 doest not have certs.
Provide certs for all guards.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

Meridian @ Braddock Station

ADDRESS: 1201 Braddock Pl

MANAGED BY: U.S. Aquatics

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.2	3			
7/13/2010	Wading Pool					

VIOLATION OBSERVED 11-11-017 Light fixture over men bathroom sink does not have a shield over it.
Provide shield.

VIOLATION OBSERVED 11-11-039 Cannot read flow rate, effluent pressure, or influent pressure.
Pool must be close until problem is corrected.

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Meridian At Carlyle

ADDRESS: 401 Holland Ln

MANAGED BY: U.S. Aquatics

PHONE: 703 299-2909

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	1			
7/9/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-069 (c)

CRITICAL VIOLATION. Chlorine in chlorine vat is almost empty, there are not enough chlorine to run for the rest of the day.

Supervisor is on his way over with some liquide chlorine.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 1	Comments:

Meridian at Eisenhower Station

ADDRESS: 2351 Eisenhower Ave
PHONE: 703 549-9400
TYPE: Local Pool - Seasonal

MANAGED BY: U.S. Aquatics
At least two (2) pool personnel must be on duty during pools hours, including: 1) a certified pool

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/7/2010	Main Pool	7.4	2			
	Wading Pool					

VIOLATION OBSERVED 11-11-017 Caulking on the far corner or the pool is deteriorating.
Re-caulk.

VIOLATION OBSERVED 11-11-069 (c)' CYA is 78.
CYA needs to be at 0 - 50ppm.

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

New Brookside

ADDRESS: 601 Four Mile Rd

MANAGED BY: Jazzie Pools, Spas & Fitness

PHONE: 703 683-2600

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.2	3			
7/13/2010	Wading Pool					

VIOLATION OBSERVED 11-11-017 2 out 3 light fixtures in the filter room do not work.
Fix/replace fixtures.

VIOLATION OBSERVED 11-11-058 (a) Water quality placard is not updated.
Update placard.

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Normandy Hill

ADDRESS: 225 Normandy Hill Dr

MANAGED BY: U.S. Aquatics

PHONE: 703 370-1151

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2			
7/13/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Northampton Place Condominium

ADDRESS: 3101 N. Hampton Dr

MANAGED BY: American Pool Company

PHONE: 703 379-1571

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	2			
7/17/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Old Town Greens Townhome Association Pool

ADDRESS: 1644 Hunting Creek Dr **MANAGED BY:** U.S. Aquatics
PHONE: 703 392-6006 x 205
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.6	3	120		
	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.6	3			
	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Old Town Pool

ADDRESS: 1609 Cameron St

MANAGED BY: City of Alexandria

PHONE: 703 838-4671

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/13/2010	Main Pool	7.6	3			
	Wading Pool					

VIOLATION
OBSERVED

11-11-046

Ladder at the 4ft is loose.
Secure the concrete block to the rest of the deck.

VIOLATION
OBSERVED

11-11-069 (c)

CRITICAL VIOLATION. Chlorine in wading pool is observed at +5.0ppm.
Wading pool must be close until Cl level has been corrected.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 1	

Old Town Village LP

ADDRESS: 343 S. Fayette St

MANAGED BY: Community Pool Service

PHONE: 703 600-6000

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	1.5			
7/14/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-058 (a)

Water quality placard is not updated.

Update placard with the latest water data.

VIOLATION
OBSERVED

11-11-069 (c)

CRITICAL VIOLATION. Chlorine level in the main pool is 1.5ppm.

Raise chlorine level to 2 - 5ppm when there is the presence of cyanuric acid.

VIOLATION
OBSERVED

11-11-099

Spa temperature is 106.7°F.

Lower spa temperature to 90 - 104°F.

Total # of Non-Critical Violations: 2

Total # of Critical Violations: 1

Inspection
Comments:

Olympus Condominium

ADDRESS: 6301 Stevenson Ave

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 370-2122

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/9/2010	Main Pool	7.5	2.5	355		
	Wading Pool	7.6	3	35		

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Palazzo @ Park Center Condos

ADDRESS: 4556 Strutfield Ln

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 567-4900

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	3			
7/17/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Parc East Condominium

ADDRESS: 1225 Martha Custis Dr **MANAGED BY:** Continental Pools, Inc.
PHONE: 703 671-9000
TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/8/2010	Main Pool	7.6	3			
	Wading Pool					

- VIOLATION OBSERVED 11-11-058 (a) Water quality placard has not been used since 06/13.
Placard needs to be posted with the latest water data.
-
- VIOLATION OBSERVED 11-11-064 (b) CRITICAL VIOLATION. Chlorine vat in wading pool filter room is not in secondary containment.
Chlorine vat needs to be in 2nd containment.
-
- VIOLATION OBSERVED 11-11-069 (c)' Total Dissolved Solid in wading pool is 2780 ppm.
Lower it to 0- 1600 ppm.
-
- VIOLATION OBSERVED 11-11-069 (e) Reagent R-0013 is out.
Provide more reagent R-0013.

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 1	

Park Place Condominium

ADDRESS: 2500 N. Van Dorn St

MANAGED BY: Sunset Pool Management

PHONE: 703 578-4400

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.5	3	350		
7/8/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Parkfairfax A

ADDRESS: 1117 Martha Custis Dr **MANAGED BY:** High Sierra Pools, Inc
PHONE: 703 578-3427
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	1			
7/8/2010	Wading Pool					

VIOLATION 11-11-069 (c)' pH in wading pool = 8.0
 OBSERVED *Lower pH to 7.2 - 7.8*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Parkfairfax B

ADDRESS: 3716 Lyons Ln

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 920-1750

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/16/2010	Main Pool	7.4	2.5			
	Wading Pool					

VIOLATION
OBSERVED

11-11-039

Flow rate observed at 265GPM.

Required flow is 270GPM.

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Parkfairfax C

ADDRESS: 3314 Coryell Lane

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 578-3427

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	4			
7/14/2010	Wading Pool					

VIOLATION 11-11-017 Return inlet cover is loose.
OBSERVED *Secure cover.*

VIOLATION 11-11-046 Chemical bucket laying outside filter room door.
OBSERVED *Remove it from deck.*

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Parkside at Alexandria

ADDRESS: 1523 N. Van Dorn St

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 426-1406

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.4	3	350		
DATE: 7/10/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Parkwood Court

ADDRESS: 101 N. Ripley St

MANAGED BY: American Pool Company

PHONE: 703 317-9484

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	1.5	300		
7/7/2010	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) No records of testing for calcium hardness, total alkalinity, and CYA.
Test weekly and record in log book kept onsite.

VIOLATION OBSERVED 11-11-064 (b) CRITICAL VIOLATION. 'No Diving' safety stencils have faded.
Re-stencil or provide signs with letterings at least five inches in height.

Total # of Non-Critical Violations: 1	Inspection	Wading pool was closed by pool mgmt company prior to
Total # of Critical Violations: 1	Comments:	inspection because chlorinator was not working

Pavilion On The Park Condominium

ADDRESS: 5340 Holmes Run Pkwy **MANAGED BY:** Community Pool Service

PHONE: 703 370-6302

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/7/2010	Main Pool	7.6	3	220		
	Wading Pool					

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection	Hose bib by drinking fountain leaks
Total # of Critical Violations: 0	Comments:	

Place One Condo

ADDRESS: 5500 Holmes Run Pkwy **MANAGED BY:** American Pool Company
PHONE: 703 370-1776
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/7/2010	Main Pool	7.8	1.5	320		
	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) No records of testing for calcium hardness, total alkalinity, and CYA in log book.
Test weekly and record test results. Keep records onsite.

VIOLATION OBSERVED 11-11-139 This is a Repeat Violation. One of two light fixtures lacks shielding in temporary men's bathroom
Shield light fixture

VIOLATION OBSERVED 11-11-139 This is a Repeat Violation. Two of three light fixtures lack shielding in the other temp mens bathroom
Shield light fixtures

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 0	

Plaza Condominium Pool

ADDRESS: 801 N. Howard St

MANAGED BY: Winkler Pool Management

PHONE: 703 823-4881

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	2			
7/16/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-017

This is a Repeat Violation. Handrailings & ladders are loose.

Secure all railings tightly.

VIOLATION
OBSERVED

11-11-017

This is a Repeat Violation. One of the two caps for the comparator is missing.

Provide missing cap.

VIOLATION
OBSERVED

11-11-045

This is a Repeat Violation. 3 Weirs missing.

Install missing weirs.

Total # of Non-Critical Violations: 3

Total # of Critical Violations: 0

Inspection
Comments:

Pointe At Park Center, The

ADDRESS: 3302 Wyndham Cir

MANAGED BY: American Pool Company

PHONE: 703 671-7368

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2			
7/17/2010	Wading Pool					

VIOLATION 11-11-017 One weir is missing.
OBSERVED *Replace missing weir.*

VIOLATION 11-11-056 Algae growth at the deep end (shaded area) of the pool.
OBSERVED *Clean up algae growth.*

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Porto Vecchio

ADDRESS: 1250 S. Washington St **MANAGED BY:** High Sierra Pools, Inc
PHONE: 703 684-3800
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.8	3			
7/9/2010	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Post Carlyle Square

ADDRESS: 501 Holland Avenue

MANAGED BY: Winkler Pool Management

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.6	2			
DATE: 7/9/2010	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) Water quality placard is not updated.
Post latest water data on placard.

VIOLATION OBSERVED 11-11-123 Fill spout is leaking and algae is presence.
Clean up algae growth and fix leak.

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Potomac Greens

ADDRESS: 1784 Potomac Greens Dr. **MANAGED BY:** Community Pool Service

PHONE: 703 653-3362

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.6	3	?		
	Wading Pool					

VIOLATION 11-11-039 Flow meter is stuck at 0
OBSERVED *Fix flow meter prior to opening tomorrow*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.4	3			
	Wading Pool					

VIOLATION 11-11-064 (b) CRITICAL VIOLATION. Missing "No Diving" sign w/
OBSERVED lettering of at least 5" in height.
Provide sign.

VIOLATION 11-11-135 This is a Repeat Violation. Shower temperature =
OBSERVED 125.0°F.
Lower temperature to 90 - 110°F within 24hours.

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 1	Comments:

Potowmack Crossing

ADDRESS: 1600 W. Abingdon Dr
PHONE: 703 548-1414
TYPE: Local Pool - Seasonal

MANAGED BY: Titan Pool Service

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/17/2010	Main Pool	7.8	2	65		
	Wading Pool					

VIOLATION OBSERVED 11-11-037 This is a Repeat Violation. Flow rate is 65 GPM
Raise to 76 GPM

VIOLATION OBSERVED 11-11-059 Water quality placard last updated July 9
Update with latest water quality test results, time, & date

VIOLATION OBSERVED 11-11-069 (c)' C.H. is 140 ppm
Raise to 150-1000 ppm

VIOLATION OBSERVED 11-11-069 (c)' T.A. is 30 ppm
Raise to 60-180 ppm

Total # of Non-Critical Violations: 4	Inspection Comments: Pool operator performed backwash and checked hair/lint strainer (removed basket which was already clean of debris) at time of inspection. Flow rate at meter did not improve
Total # of Critical Violations: 0	

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.4	1.5			
	Wading Pool					

VIOLATION OBSERVED 11-11-017 This is a Repeat Violation. Handrail at the 4ft depth marking is loose.
Secure handrail.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Princess Street Town House Assoc.

ADDRESS: 415 N. Fairfax St

MANAGED BY: American Pool Company

PHONE: 703 548-7765

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/6/2010	Main Pool	7.6	3.0			
	Wading Pool					

VIOLATION OBSERVED 11-11-059 This is a Repeat Violation. Missing water quality placard.
Provide placard w/ latest water data posted.

VIOLATION OBSERVED 11-11-069 (c)' C.H. is 130.
Increase it to 150 - 1000.

VIOLATION OBSERVED 11-11-069 (c)' T.A. = 50.
Total Alkalinity needs to be 60 - 180.

VIOLATION OBSERVED 11-11-069 (e) Could not perform CYA test.
Provide a test kit that can perform CYA test.

Total # of Non-Critical Violations: 4	Inspection
Total # of Critical Violations: 0	Comments:

Quaker Hill

ADDRESS: 1175 Quaker Hill Dr

MANAGED BY: Continental Pools, Inc.

PHONE: 703 941-9002

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/16/2010	Main Pool	7.6	3.5			
	Wading Pool					

VIOLATION
OBSERVED

11-11-059

This is a Repeat Violation. Water quality placard is not updated.

Update placard with the latest water data.

VIOLATION
OBSERVED

11-11-064 (b)

CRITICAL VIOLATION. Vacuum port is not capped.

Cap vacuum port.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 1	

Reserve @ Eisenhower Pool

ADDRESS: 5000 Eisenhower Ave

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 751-4100

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	2			
7/13/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-056

Yellow/greenish stain in the pool on the water fountain side appears to have algae growth.

Clean up stain/algae growth.

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Reserve @ Potomac Yard

ADDRESS: 3700 Jefferson Davis Hwy **MANAGED BY:** High Sierra Pools, Inc

PHONE: 703 299-0300

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.3	3	180		
7/17/2010	Wading Pool					

VIOLATION OBSERVED 11-11-099 Missing thermometer in spa pool
Provide a thermometer at the spa

VIOLATION OBSERVED 11-11-099 This is a Repeat Violation. Spa temp is 107 F
Lower to max 104 F

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	0			
7/14/2010	Wading Pool					

VIOLATION OBSERVED 11-11-064 (a) CRITICAL VIOLATION. Body hook is not attached to long pole.
Attach body hook to pole.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Chlorine in both pools are low. No one was in the pool.
Pools must be closed until violation has been corrected.

VIOLATION OBSERVED 11-11-099 spa temperature is 107.5°F.
Lower temperature to 90 - 104°F.

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 2	Comments:

Residence Inn Alexandria Old Town (Pool)

ADDRESS: 1456 Duke St

MANAGED BY: Sunset Pool Management

PHONE: 703 548-5474

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/9/2010	Main Pool	7.8	1.6			
	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) Water quality placard is not updated.
Update placard.

VIOLATION OBSERVED 11-11-069 (c)' C.H. is at 120ppm.
Raise C.H. to 150 - 1000ppm.

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Reynolds Prospect

ADDRESS: 240 S. Reynolds St

MANAGED BY: Premier Aquatics

PHONE: 703 532-5005

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	4	52		
7/16/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Riverton Condominium

ADDRESS: 610 Bashford Ln

MANAGED BY: Continental Pools, Inc.

PHONE: 703 600-6000

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	4			
7/15/2010	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) CYA, T.A., & C.H. are not recorded weekly in the chemical log book.
Record these 3 tests weekly.

VIOLATION OBSERVED 11-11-059 This is a Repeat Violation. Water quality placard is not being used.
Update placard with the latest water data.

VIOLATION OBSERVED 11-11-069 (c)' Cyanuric acid level is observed at 59.
Lower CYA to 0 - 50ppm

Total # of Non-Critical Violations: 3	Inspection
Total # of Critical Violations: 0	Comments:

Rixse Pool - Chinquapin

ADDRESS: 3210 King St

MANAGED BY: City of Alexandria

PHONE: 703 746-5435

TYPE: Local Pool - Year Round

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/10/2010	Main Pool	7.4	2			
	Wading Pool					

VIOLATION OBSERVED 11-11-063 (b) CRITICAL VIOLATION. 3 out of 4 guards' certificates are expired.
Need to show proof of valid certificates.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Combined chlorine is 0.4ppm.
Lower C.C. to 0 - 0.2ppm.

VIOLATION OBSERVED 11-11-069 (c)' T.A. is 200.
Lower Total Alkalinity to 60 - 180.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 2	

Saint Asaph Square Condominium

ADDRESS: 801 S. Pitt St

MANAGED BY: U.S. Aquatics

PHONE: 703 569-5797

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/9/2010	Main Pool	7.6	3			
	Wading Pool					

VIOLATION
OBSERVED

11-11-046

Tiles around deck drain by the flower pot is missing.
Repair/replace tiles around drainage.

VIOLATION
OBSERVED

11-11-058 (a)

water quality placard is not completely filled with all the
required information.
Fill all required information.

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Saxony Square Condominium

ADDRESS: 517 N. Armistead St **MANAGED BY:** High Sierra Pools, Inc
PHONE: 703 354-2211
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	8	2	190		
	Wading Pool	8+	10+	26		

VIOLATION OBSERVED 11-11-008 CRITICAL VIOLATION. Chlorine in wading pool is 10+, pH is 8+
Wading pool closed by health dept until chlorine is 1-5 ppm and pH is 7.2-7.8

VIOLATION OBSERVED 11-11-037 Flow rate of main pool is 190 gpm
Raise to min 205 gpm

VIOLATION OBSERVED 11-11-064 (b) CRITICAL VIOLATION. 1 of 2 chlorine vats lacks secondary containment.
Provide secondary containment.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Chlorine in wading pool exceeds 10 ppm
Lower to 1 - 5 ppm

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. pH in wading pool is 8
Lower to 7.2 - 7.8

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. pH in wading pool is 8+
Lower to 7.2 - 7.8

VIOLATION OBSERVED 11-11-135 Liquid soap dispensers are empty
Always have soap in soap dispensers

VIOLATION OBSERVED 11-11-137 Soap dispensers at sinks are empty
Always have soap in soap dispensers

Total # of Non-Critical Violations: 3	Inspection Comments: Issued \$100 civil fines 11-03465 for pH of 8 and 11-03466 for lack of CI vat secondary containment. Wading pool closed by health dept until chlorine is 1-5 ppm and pH is 7.2-7.8
Total # of Critical Violations: 5	

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Follow-up						
DATE: 7/6/2010	Main Pool	7.8	2	200		
	Wading Pool	7.5	3	26		

VIOLATION OBSERVED No observed violations were recorded.

Total # of Non-Critical Violations: 0
Total # of Critical Violations: 0

Inspection Comments: The purpose of this visit was to test the water chemistry of the wading pool after closer earlier today. Wading pool is now open for use

Seasons Condo

ADDRESS: 5801 Quantrell Ave, #2 **MANAGED BY:** Continental Pools, Inc.

PHONE: 703 354-7800

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/7/2010	Main Pool	7.6	5	350		
	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Seminary Hill Apartments

ADDRESS: 4820 Kenmore Ave

MANAGED BY: Titan Pool Service

PHONE: 703 751-8992

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/8/2010	Main Pool	7.6	3	325		
	Wading Pool	7.2	5	40		

VIOLATION OBSERVED 11-11-037 Flow rate for wading pool is 40 GPM
Raise to 63 GPM

VIOLATION OBSERVED 11-11-059 This is a Repeat Violation. Water quality placard is not used
Update with latest water quality test results, time, & date

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 0	

Seminary Towers Apartments

ADDRESS: 4701 Kenmore Ave

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 361-3177

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/8/2010	Main Pool	7.5	3	180		
	Wading Pool	7.4	3	45		

VIOLATION
OBSERVED

11-11-037

Flow rate of main pool is 180
Raise to 240 GPM prior to opening tomorrow

VIOLATION
OBSERVED

11-11-059

Water quality placard last updated 6/11/2010
Update with latest water quality test results, time, & date

VIOLATION
OBSERVED

11-11-069 (c)'

C.H. for main pool is 130 ppm
Raise to 150 ppm

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 0	

Sentinel Of Landmark

ADDRESS: 6300 Stevenson Ave
PHONE: 703 920-1750
TYPE: Local Pool - Seasonal

MANAGED BY: High Sierra Pools, Inc

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/9/2010	Main Pool	7.4	1	350		
	Wading Pool	7.2	5	35		

VIOLATION OBSERVED 11-11-039 Wrong gauge installed on effluent pipe of wading pool.
 Have vacuum, need psi gauge
Install correct gauge

VIOLATION OBSERVED 11-11-056 Algae developing on pool wall at deep end
Remove algae

VIOLATION OBSERVED 11-11-069 (c)' C.H. of main pool is 130 ppm
Raise to 150-1000 ppm

VIOLATION OBSERVED 11-11-069 (c)' TDS of wading pool is 1730 ppm
Lower to 0-1600 ppm

Total # of Non-Critical Violations: 4	Inspection	Issued warning violation 11-03472 for calcium hardness
Total # of Critical Violations: 0	Comments:	of 130 ppm

Sheraton Suites Old Town Alexandria (Pool)

ADDRESS: 801 N. St. Asaph St

MANAGED BY: Sunset Pool Management

PHONE: 703 836-4700

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	6			
7/6/2010	Wading Pool					

VIOLATION OBSERVED 11-11-017 Spa pump motor is leaking water.
Repair leak.

VIOLATION OBSERVED 11-11-058 (a) Water quality placard is not updated.
Update placard w/ the latest water data.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Bromine in pool is 6.0ppm.
Lower bromine to 2 - 4ppm.

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 1	Comments:

South Port

ADDRESS: 6112 Edsall Rd

MANAGED BY: Winkler Pool Management

PHONE: 703 751-4200

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/14/2010	Main Pool	7.6	2.5	370		
	Wading Pool					

VIOLATION OBSERVED 11-11-038 Light fixture over filters for main pool is not providing adequate light
Repair fixture and/or replace tubes

VIOLATION OBSERVED 11-11-045 1 skimmer lid broken
Replace lid

VIOLATION OBSERVED 11-11-059 Water quality placard not updated
Update with latest water quality test results, time, & date

Total # of Non-Critical Violations: 3	Inspection
Total # of Critical Violations: 0	Comments:

Southern Towers #1

ADDRESS: 4901 Seminary Rd

MANAGED BY: Winkler Pool Management

PHONE: 703 567-4901

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/14/2010	Main Pool	7.8	5	625		
	Wading Pool	7.2	1	35		

VIOLATION OBSERVED 11-11-069 (c)' C.H. for wading pool is 120 ppm.
Raise to 150 - 1000 ppm.

VIOLATION OBSERVED 11-11-135 1 of 2 liquid soap dispensers missing from men's shower stall
Install soap dispenser

VIOLATION OBSERVED 11-11-137 Out of liquid soap for men's sink
Re-fill soap dispenser

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 0	

Strand at Alexandria

ADDRESS: 240 Yoakum Pkwy

MANAGED BY: U.S. Aquatics

PHONE: 703 370-7036

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/9/2010	Main Pool	7.6	3	130		
	Wading Pool					

VIOLATION
OBSERVED

11-11-059

Water quality placard not updated

Update with latest test results, time, & date

VIOLATION
OBSERVED

11-11-069 (d)

CRITICAL VIOLATION. CYA is 60 ppm

Lower to max 50 ppm

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 1	Comments:

Summers Grove Homeowner's Assn

ADDRESS: 899 Harrison Cir

MANAGED BY: Continental Pools, Inc.

PHONE: 703 385-1133 x3003

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.4	3			
7/15/2010	Wading Pool					

VIOLATION
OBSERVED

11-11-059

This is a Repeat Violation. Water quality placard is not being used.

Water data must be posted on the placard every other hour.

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Summit, The

ADDRESS: 260 S. Reynolds St

MANAGED BY: Premier Aquatics

PHONE: 703 751-0808

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	3	140		
7/10/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Templeton

ADDRESS: 250 S. Reynolds St

MANAGED BY: DominionAquatics

PHONE: 703 370-3714

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.6	5	140		
DATE: 7/10/2010	Wading Pool					

VIOLATION OBSERVED 11-11-058 (a) No record of testing for total alkalinity in log book
Test weekly (along with calcium hardness) and record in log book kept onsite

VIOLATION OBSERVED 11-11-059 Missing bather load placard
Post placard with minimum 2 inch letterings where patrons can read it

VIOLATION OBSERVED 11-11-059 Missing water quality placard
Post placard where patrons can read it and update with latest water quality test results, time, & date

Total # of Non-Critical Violations: 3	Inspection Comments:
Total # of Critical Violations: 0	

Tower 2000

ADDRESS: 5800 Quantrell Ave

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 354-4937 (pool)

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.5	4	250		
7/9/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Townes At Cameron Parke

ADDRESS: 3827 Dominion Mill Dr **MANAGED BY:** High Sierra Pools, Inc
PHONE: 703 361-3177
TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/13/2010	Main Pool	7.4	2			
	Wading Pool					

VIOLATION No observed violations were recorded.
OBSERVED

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Wapleton Condominium

ADDRESS: 5250 Valley Forge Dr

MANAGED BY: Premier Aquatics

PHONE: 703 370-1600

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.8	3	200		
7/15/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Warwick Village

ADDRESS: 3301 Landover St

MANAGED BY: City of Alexandria

PHONE: 703 746-5435

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/14/2010	Main Pool	7.4	3			
	Wading Pool					

VIOLATION OBSERVED 11-11-040 This is a Repeat Violation. Missing extra hair/lint basket for wading pool.
Provide extra basket.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. Chlorine for wading pool is observed at +5.
Lower Cl to 1 - 5ppm.

VIOLATION OBSERVED 11-11-069 (c)' pH for wading pool is observed at 7.0.
Raise pH to 7.2 - 7.8.

Total # of Non-Critical Violations: 2	Inspection Comments:
Total # of Critical Violations: 1	

Washington Suites - Alexandria (Pool)

ADDRESS: 100 S. Reynolds St

MANAGED BY: Winkler Pool Management

PHONE: 703 370-9600

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.8	1.5	280		
7/13/2010	Wading Pool					

VIOLATION OBSERVED 11-11-056 Algae on deck near guard table
Clean deck

VIOLATION OBSERVED 11-11-056 Deck drain at 3ft depth corner of pool farthest from building is clogged
Unclog deck drain

VIOLATION OBSERVED 11-11-069 (c)' TDS is 1790 ppm
Lower to 0-1600 ppm

Total # of Non-Critical Violations: 3	Inspection
Total # of Critical Violations: 0	Comments:

Watergate At Landmark

ADDRESS: 211 Yoakum Pkwy

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 370-7001

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE:	Main Pool	7.6	5	825		
7/15/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

Watergate At Landmark (Indoor)

ADDRESS: 211 Yoakum Pkwy

MANAGED BY: High Sierra Pools, Inc

PHONE: 703 370-7000

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/15/2010	Main Pool	7.6	2	240		
	Wading Pool					

VIOLATION
OBSERVED

11-11-069 (c)

CRITICAL VIOLATION. Combined chlorine in pool is 0.4 ppm
Lower to 0-0.2 ppm

VIOLATION
OBSERVED

11-11-103

This is a Repeat Violation. Total alkalinity of spa is 30 ppm
Raise to 60-180 ppm

Total # of Non-Critical Violations: 1
Total # of Critical Violations: 1

Inspection Comments: Issued \$100 civil fine 11-03551 for total alkalinity of spa at 30 ppm

Wesley Parc View Apartments

ADDRESS: 5380 Holmes Run Pkwy **MANAGED BY:** Winkler Pool Management

PHONE: 703

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/14/2010	Main Pool	7.8	0.5	175		
	Wading Pool	7.2	0	30		

VIOLATION OBSERVED 11-11-058 (a) No records of testing for T.A. and C.H.
Test each at least one time per week and record in log book.

VIOLATION OBSERVED 11-11-059 Water quality placard last updated 7/11/2010
Update with latest water quality test results, time, & date

VIOLATION OBSERVED 11-11-064 (a) CRITICAL VIOLATION. Body hook is broken.
Repair hook and attach to pole during pool hours.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. CI in main pool is 0.5.
Raise to 1 - 5 ppm.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. CI in wading pool is 0.
Raise to 1 - 5 ppm.

VIOLATION OBSERVED 11-11-069 (c)' TDS for main pool is 1830 ppm.
Lower to 0 - 1600 ppm.

Total # of Non-Critical Violations: 3	Inspection
Total # of Critical Violations: 3	Comments:

Westin Alexandria (Pool), The

ADDRESS: 400 Courthouse Sq

MANAGED BY: Sunset Pool Management

PHONE: 703 253-8600

TYPE: Local Pool - Year Round

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/7/2010	Main Pool	7.6	2			
	Wading Pool					

VIOLATION
OBSERVED

11-11-099

Spa temperature is 106*F.

*Reduce temperature to 90 - 104*F.*

Total # of Non-Critical Violations: 1	Inspection
Total # of Critical Violations: 0	Comments:

Willow Run

ADDRESS: 5400 Richenbacher Ave
PHONE: 703 578-7840
TYPE: Local Pool - Seasonal

MANAGED BY: High Sierra Pools, Inc
This facility must maintain the higher required chlorine residual (3ppm – 5ppm) and restrict its ba

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine						
DATE: 7/6/2010	Main Pool	7.6	5	350		
	Wading Pool	7.6	3	50		

VIOLATION 11-11-017 Crack/Deterioration on deck at fill spout end of pool
 OBSERVED *Patch deck*

Total # of Non-Critical Violations: 1	Inspection Comments:
Total # of Critical Violations: 0	

Windsor At Arbors

ADDRESS: 5250 Duke St

MANAGED BY: U.S. Aquatics

PHONE: 703 823-0681

TYPE: Local Pool - Seasonal

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/13/2010	Main Pool					
	Wading Pool					

VIOLATION OBSERVED 11-11-047 1 light has fallen off pool wall
Repair light within 24 hours

VIOLATION OBSERVED 11-11-066 (a) Showering placard missing.
Post as per 11-11-66 (a) where patrons can read it prior to entering the pool area.

Total # of Non-Critical Violations: 2	Inspection
Total # of Critical Violations: 0	Comments:

Woodmont Park

ADDRESS: 5465 N. Morgan St

MANAGED BY: Winkler Pool Management

PHONE: 703 567-2200

TYPE: Local Pool - Seasonal

INSPECTION:		PH	Chlorine	Flow	Temp	Pressure
Routine	Main Pool	7.8	5	250		
DATE: 7/7/2010	Wading Pool					

VIOLATION
OBSERVED

No observed violations were recorded.

Total # of Non-Critical Violations: 0	Inspection
Total # of Critical Violations: 0	Comments:

XSport Fitness

ADDRESS: 4300 King St

MANAGED BY: Self-Managed

PHONE: 703 933-9333

TYPE: Local Pool - Year Round

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/6/2010	Main Pool					
	Wading Pool					

VIOLATION OBSERVED 11-11-064 (b) CRITICAL VIOLATION. Acid vat in filter room for pools lack secondary containment.
Provide secondary containment.

VIOLATION OBSERVED 11-11-069 (c) CRITICAL VIOLATION. This is a Repeat Violation. Combined chlorine for pool is 0.6 ppm
Lower to 0 - 0.2 ppm.

VIOLATION OBSERVED 11-11-069 (c)' TDS for pool is 5000.
Lower to max 4600 ppm.

VIOLATION OBSERVED 11-11-103 This is a Repeat Violation. C.C. for spa is 1.4 ppm
Lower to 0-0.2 ppm

VIOLATION OBSERVED 11-11-103 This is a Repeat Violation. T.A. for spa is 50 ppm
Raise to 60-180 ppm

VIOLATION OBSERVED 11-11-103 TDS for spa is 6380
Lower to max 4600 ppm

Total # of Non-Critical Violations: 4	Inspection Comments:	Issued \$100 civil fine 10-03464 for combined chlorine residual in spa of 1.4 ppm & in pool of 0.6 ppm
Total # of Critical Violations: 2		

YMCA

ADDRESS: 420 E. Monroe Ave

MANAGED BY: Self-Managed

PHONE: 703 838-8085

TYPE: Local Pool - Year Round

INSPECTION: Routine		PH	Chlorine	Flow	Temp	Pressure
DATE: 7/10/2010	Main Pool	7.6	3			
	Wading Pool					

VIOLATION
OBSERVED

11-11-039

Flow rate observed at 250GPM.

The minimum requirement is 275 GPM for this system.

VIOLATION
OBSERVED

11-11-069 (c)

CRITICAL VIOLATION. This is a Repeat Violation.
Combined chlorine observed at 0.4ppm.

Lower C.C. to 0-0.2ppm.

Total # of Non-Critical Violations: 1

Total # of Critical Violations: 1

Inspection
Comments: