

MIRANT COMMUNITY GROUP MEETING

NOVEMBER 8, 2007

HANDOUTS

ATTACHMENT	DESCRIPTION	PAGE
A	June 1, 2007 State Operating Permit for PRGS	1
B	VDEQ Proposed Comprehensive State Operating Permit for PRGS including:	17
	• Letter from Jim Sydnor to SAPCB Members	19
	• Stationary Source Permit to Operate (5 Stack Version)	21
	• VDEQ Statement of Legal and Factual Basis	45
	• Public Notice for Comment on a Draft State Operating Permit for the Mirant Potomac River LLC's PRGS Recommended by the Department of Environmental Quality	73
C	City's Letter to SAPCB Members, Permit Requirement for Stack Merger Project, Mirant PRGS, September 12, 2007	79
	City's Letter to David Paylor and SAPCB Members, New Source Review Permit for Construction of Stack Merger and Comprehensive SOP for Mirant PRGS, October 5, 2007	87
	City's Letter to David Paylor and SAPCB Members, Comprehensive SOP (2 Stack version) for Mirant PRGS, October 9, 2007	103
D	City's Letter to Mary Major, VDEQ, Comments on the Changes to the Final Regulation for Emissions Trading (CAIR), June 12, 2007	109
	City's Letter to Doris McLeod, VDEQ, Comments on Virginia SIP Revision for Certification of § 110(a)(2)(D)(i) Requirements for the 8-Hour Ozone and PM _{2.5} NAAQS, October 17, 2007	111
E	Virginia Department of Health, Report on "Health Effects Associated with Exposure to Trona - A Review of the Biomedical Literature, June 2007"	117
F	City's Presentations to the SAPCB on May 22, 2007 and September 13, 2007	137
G	PJM Letter to The Honorable Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, September 24, 2007	145
H	MCMG Tracking Matrix - 11-07-07 Updated Version	155
I	Outline of City's Comments on VDEQ Proposed Comprehensive State Operating Permits and SAPCB's Seven Technical Questions	185

ATTACHMENT A

June 1, 2007 State Operating Permit for PRGS



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY
100 EAST MAIN STREET, ROOM 301, ALEXANDRIA, VA 22304
MAIL STOP 100, ALEXANDRIA, VA 22304-0100
TEL: 703-298-1000 FAX: 703-298-1000
WWW.DEQ.VIRGINIA.GOV

June 1, 2007

Mr. Robert E. Driscoll
President & Chief Executive Officer
Mirant Potomac River, LLC
1400 North Royal Street
Alexandria, Virginia 22314

Location: Alexandria
Registration No.: 70228
County Plant No.: 510-00003

Dear Mr. Driscoll:

Attached is a permit to operate an electricity generating facility in accordance with the provisions of the Commonwealth of Virginia State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution.

This permit contains legally enforceable conditions. Failure to comply may result in a Notice of Violation and civil penalty. Please read all permit conditions carefully.

In the course of evaluating the data and arriving at a final decision to approve the permit, the Department of Environmental Quality (DEQ) solicited written public comments by placing an advertisement in the *Alexandria Journal* and on the DEQ public and the Virginia Town Hall web pages on April 21, 2007. A public hearing was held on May 22, 2007. The required comment period, provided by 9 VAC 5-80-1020 A, expired on May 21, 2007.

This approval to operate shall not relieve Mirant Potomac River, LLC of the responsibility to comply with all other local, state, and federal permit regulations.

The Board's Regulations as contained in Title 9 of the Virginia Administrative Code 5-170-200 provide that you may request a formal hearing from this case decision by filing a petition with the Board within 30 days after this case decision notice was mailed or delivered to you. 9 VAC 5-170-180 provides that you may request direct consideration of the decision by the

Board if the Director of the DEQ made the decision. Please consult the relevant regulations for additional requirements for such requests.

As provided by Rule 2A:2 of the Supreme Court of Virginia, you have 30 days from the date of service of this decision (the date you actually received this decision or the date on which it was mailed to you, whichever occurred first), within which to initiate an appeal of this decision by filing a Notice of Appeal with:

David K. Paylor, Director
Department of Environmental Quality
P. O. Box 1105
Richmond, VA 23218

In the event that this decision is served on you by mail, three days are added to the period in which to file an appeal. Please refer to Part Two A of the Rules of the Supreme Court of Virginia for information on the required content of the Notice of Appeal and for additional requirements governing appeals from decisions of administrative agencies.

If you have any questions concerning this permit, please call the central office at (804) 698-4366.

Sincerely,



David K. Paylor, Director
Department of Environmental Quality

DKP/TDB/Mirant SOP_Cover_Letter.doc

Attachment: Permit

CC: Director, OAPP (electronic file submission)
Manager, Data Analysis (electronic file submission)
Permits and Technical Assessment Branch, U.S. EPA, Region III (electronic file submission)



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

Street address: 629 East Main Street, Richmond, Virginia 23219

Mailing address: P.O. Box 1165, Richmond, Virginia 23218

Tel: (804) 698-4500 *FDDI:* (804) 698-4621

www.ecq.virginia.gov

T. Preston Bryant, Jr.
Secretary of Natural Resources

David K. Paylor
Director

(804) 698-4400
Fax: (804) 698-4487

STATIONARY SOURCE PERMIT TO OPERATE

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

Mirant Corporation
8711 Westphalia Road
Upper Marlboro, MD 20774
Registration No.: 70228

is authorized to operate

an electricity generating facility

located at

1400 North Royal Street
Alexandria, VA 22314

in accordance with the Conditions of this permit.

Approved on **June 1, 2007.**

David K. Paylor, Director
Department of Environmental Quality

Permit consists of 12 pages.
Permit Conditions 1 to 23.

INTRODUCTION

This permit approval is issued in accordance with the Air Pollution Control Board's authority under 9 VAC 5-80-800.C.2. Any changes in existing facilities which alter the impact of the facility on air quality may require a permit. Failure to obtain such a permit prior to construction may result in enforcement action. In addition, this facility may be subject to additional applicable requirements not listed in this permit.

Words or terms used in this permit shall have meanings as provided in 9 VAC 5-10-20 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. The regulatory reference or authority for each condition is listed in parentheses () after each condition.

Annual requirements to fulfill legal obligations to maintain current stationary source emissions data will necessitate a prompt response by the permittee to requests by the DEQ or the Board for information to include, as appropriate: process and production data; changes in control equipment; and operating schedules. Such requests for information from the DEQ will either be in writing or by personal contact.

The availability of information submitted to the DEQ or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the Board) of the Code of Virginia, and 9 VAC 5-170-60 of the State Air Pollution Control Board Regulations. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

PROCESS REQUIREMENTS

I. **Equipment List** - Equipment at this facility consists of the following:

Equipment to be modified			
Reference No.	Equipment Description	Maximum Rated Capacity	Manufactured Date
C1	Combustion Engineering, natural circulation, tangentially coal-fired with superheater and economizer with low NO _x burners.	970.1 mmBtu/hr	1949
C2	Combustion Engineering, natural circulation, tangentially coal-fired with superheater and economizer with low NO _x burners.	970.1 mmBtu/hr	1950
C3	Combustion Engineering, natural circulation, tangentially coal-fired with superheater and economizer with low NO _x burners and over fired air.	960.7 mmBtu/hr	1954
C4	Combustion Engineering, natural circulation, tangentially coal-fired with superheater and economizer with low NO _x burners and over fired air.	960.7 mmBtu/hr	1956
C5	Combustion Engineering, natural circulation, tangentially coal-fired with superheater and economizer with low NO _x burners and over fired air.	960.7 mmBtu/hr	1957
Trona Handling	Pneumatic upload system, full enclosure	n/a	n/a

Specifications included in the permit under this Condition are for informational purposes only and do not form enforceable terms or conditions of the permit.

(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

2. **SO₂ Emission Controls** – SO₂ emissions from boilers C1, C2, C3, C4, and C5 shall be controlled by the use of low sulfur coal and trona injection. The permittee shall maintain and operate a trona injection system on all five units at the facility. The permittee shall inject trona into the exhaust stream of each unit while the unit is operating.
(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)
3. **Monitoring** – A Continuous Opacity Monitoring System (COMS) shall be utilized to measure and record the opacity of emissions from the stacks of boilers C1, C2, C3, C4, and C5. The monitors shall be maintained and calibrated in accordance with 9 VAC 5-40-41 of State Regulations.
(9 VAC 5-80-850, 9 VAC 5-40-40, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)
4. **Monitoring** – A Continuous Emission Monitoring System (CEMS) and a flow monitoring system, each with an automated data acquisition and handling system, shall be utilized to measure and record the emissions of SO₂ from boilers C1, C2, C3, C4, and C5. The automated data acquisition and handling systems shall measure and record SO₂ concentration (in ppm), volumetric gas flow (in scfh), and SO₂ mass emissions (in lbs/hr) discharged to the atmosphere. The CEMS shall be certified, operated, and maintained according to approved procedures in accordance with the provisions of 40 CFR Part 75. The permittee shall utilize measured and recorded CEMS data to calculate short-term SO₂ emissions in pounds per million Btu, pounds per hour, and pounds per day; and annual SO₂ emissions in tons per year. SO₂ emissions in pounds per hour shall be calculated as the average of each 3-hour block period. SO₂ emissions in pounds per million Btu shall be calculated as the average of each block 3-hour period and as the average of each block 24-hour period beginning at 12:01 AM each calendar day. Daily SO₂ emissions in pounds per day shall be calculated daily as the sum of hourly emissions for each block 24-hour period beginning at 12:01 AM each calendar day. Annual SO₂ emissions shall be calculated monthly as the sum of each consecutive 12-month period. Calculations shall be maintained on-site for the most recent 5-year period and shall demonstrate compliance with the emission limitations set forth in Conditions 9 and 10.
(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)
5. **Ambient Air Monitoring** – The permittee shall continue to operate the six (6) existing SO₂ monitors to measure, record, and report the ambient concentration of SO₂ from the stacks of boilers C1, C2, C3, C4, and C5 as outlined in Section IV.B.7 of the EPA Administrative Compliance Order (ACO) by Consent dated June 1, 2006. The permittee shall continue to submit all ambient monitoring reports as specified in the EPA ACO to the Director, Department of Environmental Quality. The monitors shall be operated, maintained, and subject to the appropriate QA/QC provisions as set forth in Appendix A of 40 CFR Part 58. This condition shall cease to apply 12-months following issuance of this permit unless extended in writing by the Director, Department of Environmental Quality.
(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

OPERATING LIMITATIONS

6. **Fuel** - The approved fuels for boilers C1, C2, C3, C4 and C5 are coal and distillate oil. A change in the fuel may require a permit to modify and operate.
(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

7. **Fuel** - The coal and distillate oil shall meet the specifications below:
COAL:
Maximum heat content: 12,800 Btu/lb HHV
as determined by ASTM D2015, D3286, or a DEQ-approved equivalent method.

Maximum sulfur content per shipment: 0.9 %
as determined by STM D3177, D4239, or a DEQ-approved equivalent method

Maximum ash content per shipment: 11.0%
as determined by ASTM D3174, or a DEQ-approved equivalent method.

DISTILLATE OIL which meets the ASTM D396 specification for numbers 1 or 2 fuel oil:
Maximum sulfur content per shipment: 0.8%
(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

8. **Fuel Certification** - The permittee shall obtain a certification from the fuel supplier with each shipment of coal and distillate oil. Each fuel supplier certification shall include the following:
 - a. The name of the fuel supplier;
 - b. The date on which the coal or distillate oil was received;
 - c. The quantity of coal or distillate oil delivered in the shipment;
 - d. A statement that the distillate oil complies with the American Society for Testing and Materials specifications (ASTM D396) for numbers 2 fuel oil;
 - e. The sulfur content of the coal or distillate oil;
 - f. Documentation of sampling of the coal or distillate oil indicating the location of the fuel when the sample was taken; and;
 - g. The methods used to determine the sulfur and ash contents of the coal;

Fuel sampling and analysis, independent of that used for certification, as may be periodically required or conducted by DEQ may be used to determine compliance with the fuel specifications stipulated in Condition 7. Exceedance of these specifications may be considered credible evidence of the exceedance of emission limits.
(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

EMISSION LIMITS

9. **Boiler Emission Limits** – SO₂ emissions from the operation of boilers C1, C2, C3, C4, and C5 shall not exceed the limits specified below:

<i>Scenario</i>	<i>Units On</i>	<i>Operating Hours</i>	<i>Averaging Period</i>	<i>SO₂ Rate (lb/MMBtu)[▲]</i>	<i>SO₂ Rate (lb/hour)[*]</i>	<i>SO₂ Rate (lb/day)^{**}</i>
1a	3 & 4	Both Units @ 16 hrs max/ 8 hrs min	3-hour	0.38	800	15,150
			24-hour	0.44		
1b	3 & 4	Both Units @ 12 hrs max/ 12 hrs min	3-Hour	0.38	800	13,126
			24-Hour	0.42		
2a	3 & 5	Both Units @ 16 hrs max/ 8 hrs min	3-Hour	0.43	914	17,281
			24-Hour	0.46		
2b	3 & 5	Both units @ 12 hrs max/ 12 hrs min	3-Hour	0.43	914	14,956
			24-Hour	0.45		
3a	4 & 5	Both Units @ 16 hrs max/ 8 hrs min	3-Hour	0.42	921	17,401
			24-Hour	0.45		
3b	4 & 5	Both units @ 12 hrs max/ 12 hrs min	3-Hour	0.42	921	15,044
			24-Hour	0.43		
4a	1,2,3	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 3 @ 16 hrs max/ 8 hrs min	3-Hour	0.34	1,054	14,838
			24-Hour	0.40		
4b	1,2,3	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 3 @ 12 hrs max/ 12 hrs min	3-Hour	0.34	1,054	14,605
			24-Hour	0.40		
5a	1,2,4	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 4 @ 16 hrs max/ 8 hrs min	3-Hour	0.36	1,141	16,158
			24-Hour	0.40		
5b	1,2,4	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 4 @ 12 hrs max/ 12 hrs min	3-Hour	0.36	1,141	15,838
			24-Hour	0.40		
6a	1,2,5	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 16 hrs max/ 8 hrs min	3-Hour	0.40	1,240	17,456
			24-Hour	0.43		
6b	1,2,5	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 12 hrs max/ 12 hrs min	3-Hour	0.40	1,240	17,182
			24-Hour	0.43		
7a	3,4,5	All units @ 16 hrs max/ 8 hrs min	3-Hour	0.28	899	17,008
			24-Hour	0.30		
7b	3,4,5	All units @ 12 hrs max/ 12 hrs min	3-Hour	0.28	899	14,720
			24-Hour	0.30		

Scenario	Units On	Operating Hours	Averaging Period	SO ₂ Rate (lb/MMBtu) [▲]	SO ₂ Rate (lb/hour)*	SO ₂ Rate (lb/day)**
7c	3,4,5	All units @ 8 hrs max/ 16 hrs min	3-Hour	0.28	835	11,544
			24-Hour	0.26		
8a	1	8 hrs max/ 8 hrs min/ 8 hrs off	3-Hour	1.26	1,327	15,553
			24-Hour	1.51		
8b	1	16 hrs max/ 8 hrs off	3-Hour	1.24	1,306	20,892
			24-Hour	1.64		
9a	2	8 hrs max/ 8 hrs min/ 8 hrs off	3-Hour	1.02	1,050	12,224
			24-Hour	1.29		
9b	2	16 hrs max/ 8 hrs off	3-Hour	0.96	988	15,805
			24-Hour	1.14		
10a	3	12 hrs max/ 12 hrs min	3-Hour	0.75	764	12,564
			24-Hour	0.84		
10b	3	16 hrs max/ 8 hrs min	3-Hour	0.75	764	14,484
			24-Hour	0.90		
11a	4	12 hrs max/ 12 hrs min	3-Hour	0.79	859	14,054
			24-Hour	0.86		
11b	4	16 hrs max/ 8 hrs min	3-Hour	0.79	859	16,239
			24-Hour	0.86		
12a	5	12 hrs max/ 12 hrs min	3-Hour	0.78	863	14,063
			24-Hour	0.82		
12b	5	16 hrs max/ 8 hrs min	3-Hour	0.78	863	16,283
			24-Hour	0.92		
13a	1,2	Both units 8 hrs max/ 8 hrs min/ 8 hrs off	3-Hour	0.56	1,166	13,624
			24-Hour	0.70		
13b	1,2	Both units 16 hrs max/ 8 hrs off	3-Hour	0.54	1,124	17,988
			24-Hour	0.69		
14a	1,3	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off, Unit 3 @ 12 hrs max /12 hrs min	3-Hour	0.49	1,015	14,257
			24-Hour	0.59		
14b	1,3	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 3 @ 16 hrs max/ 8 hrs min	3-Hour	0.49	1,015	15,511
			24-Hour	0.59		
15a	1,4	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off, Unit 4 @ 12 hrs max /12 hrs min	3-Hour	0.51	1,091	15,368
			24-Hour	0.58		

Scenario	Units On	Operating Hours	Averaging Period	SO ₂ Rate (lb/MMBtu) [▲]	SO ₂ Rate (lb/hour) [*]	SO ₂ Rate (lb/day) ^{**}
15b	1,4	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 4 @ 16 hrs max/ 8 hrs min	3-Hour	0.51	1,091	16,779
			24-Hour	0.58		
16a	1,5	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 12 hrs max /12 hrs min	3-Hour	0.60	1,296	18,224
			24-Hour	0.62		
16b	1,5	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 16 hrs max/ 8 hrs min	3-Hour	0.60	1,296	19,932
			24-Hour	0.62		
17a	2,3	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 3 @ 12 hrs max /12 hrs min	3-Hour	0.45	921	12,931
			24-Hour	0.53		
17b	2,3	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 3 @ 16 hrs max/ 8 hrs min	3-Hour	0.45	921	14,083
			24-Hour	0.53		
18a	2,4	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 4 @ 12 hrs max /12 hrs min	3-Hour	0.48	1,016	14,292
			24-Hour	0.52		
18b	2,4	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 4 @ 16 hrs max/ 8 hrs min	3-Hour	0.48	1,016	15,619
			24-Hour	0.52		
19a	2,5	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 12 hrs max /12 hrs min	3-Hour	0.56	1,175	16,508
			24-Hour	0.55		
19b	2,5	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 16 hrs max/ 8 hrs min	3-Hour	0.56	1,175	18,073
			24-Hour	0.55		
20	1,3,4	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Units 3,4 @ 12 hrs max /12 hrs min	3-Hour	0.30	947	14,066
			24-Hour	0.35		
21	1,3,5	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Units 3,5 @ 12 hrs max /12 hrs min	3-Hour	0.33	1,049	15,552
			24-Hour	0.37		
22	1,4,5	Unit 1 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Units 4,5 @ 12 hrs max /12 hrs min	3-Hour	0.34	1,104	16,376
			24-Hour	0.36		
23	2,3,4	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Units 3,4 @ 12 hrs max /12 hrs min	3-Hour	0.29	909	13,493
			24-Hour	0.33		
24	2,3,5	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Units 3,5 @ 12 hrs max /12 hrs min	3-Hour	0.32	1,009	14,965
			24-Hour	0.34		
25	2,4,5	Unit 2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Units 4,5 @ 12 hrs max /12 hrs min	3-Hour	0.33	1,064	15,775
			24-Hour	0.33		

*Calculated hourly as the average of each 3-hour block period.

** Daily SO₂ emissions in pounds per day shall be calculated as the sum of hourly emissions for each block 24-hour period beginning at 12:01 AM each calendar day.

*3-hour SO₂ emissions in pounds per million Btu shall be calculated as the average of hourly emissions for each block 3-hour period beginning at 12:01 AM each calendar day; 24-hour SO₂ emissions in pounds per million Btu shall be calculated as the average of hourly emissions for each block 24-hour period beginning at 12:01 AM each calendar day.

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Condition 4. (9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

10. **Facility wide Emission Limits** - Total annual emissions of SO₂ from boilers C1, C2, C3, C4, and C5 (combined) shall not exceed the limits specified below:

	Annual (tons per year)**
Boilers C1, C2, C3, C4, and C5 (combined)	3,813

**Calculated monthly as the sum of each consecutive 12-month period.

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with these emission limits may be determined as stated in Condition 4. (9 VAC 5-80-850, 9 VAC 5-80-800.C.2, 9 VAC 5-80-820.D, and 9 VAC 5-50-260)

11. **Operating Scenarios** – Upon issuance of this permit, each calendar day the permittee shall identify and record the next calendar day’s projected operating scenario and shall record in a logbook the previous calendar day’s actual operating scenario in accordance with the scenarios outlined in Condition 9 of this permit. The logbook shall be maintained on-site for the most recent five (5) year period and shall be made available for inspection. (9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

12. **Visible Emission Limit** - Visible emissions from the boilers C1, C2, C3, C4, and C5 shall not exceed 20 percent opacity except during one six-minute period in any one hour in which visible emissions shall not exceed 30 percent opacity as determined by the EPA Method 9 (reference 40 CFR 60, Appendix A). This condition applies at all times except during startup, shutdown, and malfunction. (9 VAC 5-80-850, 9 VAC 5-40-80, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

RECORDS

13. **On Site Records** - The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. The content and format of such records shall be arranged with the Northern Virginia Regional Office. These records shall include, but are not limited to:

- a. All fuel supplier certifications.

- b. Emissions calculations and CEMS data for SO₂ from the boilers to verify compliance with the lbs/mmBtu, lbs/hour, and tons/year emission limitations in Conditions 9 and 10.
- c. CEMS, COMS, and SO₂ ambient air monitor maintenance and calibration records.
- d. All recorded COMS and SO₂ ambient air monitoring data.
- e. Daily records of the operating scenarios under which the facility operated for each calendar day as approved by the Northern Virginia Regional Office.
- f. Scheduled and unscheduled boiler maintenance and operator training.

These records shall be available for inspection by the DEQ and shall be current for the most recent five years.

(9 VAC 5-80-850, 9 VAC 5-50-50, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

NOTIFICATIONS

14. **Notifications** - The permittee shall furnish written notification to the Northern Virginia Regional Office of:
- a. The anticipated dates of any continuous monitoring system performance evaluations performed in accordance with 40 CFR Part 75 postmarked not less than 30 days prior to such date.

(9 VAC 5-50-50, 9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

ALTERNATIVE OPERATING SCENARIO

15. **Alternate Operating Scenario (Optional)** – In lieu of compliance with the provisions of this permit, the permittee may elect to comply with the following Alternate Operating Scenario until such time as the permittee is notified by the Director, Department of Environmental Quality that it has been determined that the installation of the new 230 kV transmission lines has been substantially completed. At such time as this notification is made by the Director, Department of Environmental Quality, the permittee shall cease to operate under this Alternate Operating Scenario and shall comply with the terms and conditions of this permit as specified in Specific Conditions 1 through 14 and General Conditions 16 through 22. For the purposes of this permit, the Alternate Operating Scenario shall consist of the provisions of the EPA Administrative Compliance Order (ACO) by Consent, Docket No. CAA-03-2006-0163DA, dated June 1, 2006; the Department of Energy (DOE) Order No. 202-05-3, issued by the Department of Energy on December 20, 2005, in Docket No. EO-05-01 in response to an Emergency Petition and Complaint filed by the District of Columbia Public Service Commission; and DOE Order No. 202-07-2 issued by DOE on January 31, 2007, in Docket No. EO-05-01. The EPA ACO by Consent dated June 1, 2006, is attached as Appendix 1 to this permit. The DOE Order No. 202-05-3 dated December 20, 2005, is attached as Appendix 2 to this permit. The DOE Order No. 202-07-2 dated January 31, 2007, is attached as Appendix 3 to this permit.

(9 VAC 5-80-850, 9 VAC 5-80-800.C.2 and 9 VAC 5-80-820.D)

GENERAL CONDITIONS

16. **Right of Entry** - The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:
- a. To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;
 - b. To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
 - c. To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and
 - d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency.
(9 VAC 5-170-130 and 9 VAC 5-80-850)

17. **Notification for Facility or Control Equipment Malfunction** - The permittee shall furnish notification to the Northern Virginia Regional Office of malfunctions of the affected facility or related air pollution control equipment that may cause excess emissions for more than one hour, by facsimile transmission, telephone, or telegraph. Such notification shall be made as soon as practicable but no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within two weeks of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Northern Virginia Regional Office in writing.
(9 VAC 5-20-180 C and 9 VAC 5-80-850)
18. **Violation of Ambient Air Quality Standard** - The permittee shall, upon request of the DEQ, reduce the level of operation or shut down a facility, as necessary to avoid violating any primary ambient air quality standard and shall not return to normal operation until such time as the ambient air quality standard will not be violated.
(9 VAC 5-20-180 I and 9 VAC 5-80-850)

19. **Maintenance/Operating Procedures** – At all times, including periods of start-up, shutdown, soot blowing, and malfunction, the permittee shall, to the extent practicable, maintain and operate the affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take the following measures in order to minimize the duration and frequency of excess emissions, with respect to boilers C1, C2, C3, C4, and C5.

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain an inventory of spare parts.
- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, at a minimum.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such equipment. The permittee shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.

Records of maintenance and training shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request.
(9 VAC 5-50-20 E and 9 VAC 5-80-850)

20. **Permit Suspension/Revocation** - This permit may be revoked if the permittee:

- a. Knowingly makes material misstatements in the permit application or any amendments to it;
- b. Fails to comply with the terms or conditions of this permit;
- c. Fails to comply with any emission standards applicable to a permitted emissions unit;
- d. Causes emissions from this facility which result in violations of, or interferes with the attainment and maintenance of, any ambient air quality standard;
- e. Fails to operate this facility in conformance with any applicable control strategy, including any emission standards or emission limitations, in the State Implementation Plan in effect at the time that this permit is issued;
- f. Fails to comply with the applicable provisions of Articles 6, 8 and 9 of 9 VAC 5 Chapter 80.
(9 VAC 5-80-1010)

21. **Change of Ownership** - In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current permit issued to the previous owner. The new owner shall notify the Northern Virginia Regional Office of the change of ownership within 30 days of the transfer.
(9 VAC 5-80-940)
22. **Severability** - The terms of this permit are severable. If any condition, requirement or portion of the permit is held invalid or inapplicable under any circumstance, such invalidity or inapplicability shall not affect or impair the remaining conditions, requirements, or portions of the permit.
(9 VAC 5-80-800 C.2)
23. **Permit Copy** - The permittee shall keep a copy of this permit on the premises of the facility to which it applies.
(9 VAC 5-80-860 D)